



KERALA WATER AUTHORITY
Quality Control District Laboratory, Kottakkunnu, Malappuram.

Water Analysis Report

Report No-KWA/QCDL/MPM/WAR/21-22/2438C		Date: 28.10.2021
Customer Name & Address	1. Sample Code	21-22/2438
HILL TOP Public School Kunnakkavu Elad(PO) Perinthalmanna	2. Date of Receipt	26.10.2021
	3. Sampling Done by	Party
	4. Source of Sample	Open Well
	5. Sample Quantity	1 L
	6. Sample Performance from: 26.10.2021 to 27.10.2021	

Sl. No	Characteristics	Unit	Test Method	Available Limit as per IS 10500:2012	Results
1	Colour	Pt.Co. Units	IS 3025(part 4)-1983 (Reaffirmed 2017)	5	Clear
2	Odour		IS 3025(part 5)-2018 (Reaffirmed 2017)	Agreeable	Agreeable
3	Turbidity	NTU	IS 3025(part 10)-1984 (Reaffirmed 2017)	5	0.7
4	pH		IS 3025(part 11)-1983 (Reaffirmed 2017)	6.5 - 8.5	5.23
5	Electrical Conductivity at 25°C	micro mhos/cm	IS 3025(part 14)-2013 (Reaffirmed 2019)		32.5
6	Alkalinity	mg/litre	IS 3025(part 23)-1986 (Reaffirmed 2019)	200	19.90
7	Sulphate	mg/litre	IS 3025(part 24)-1984 (Reaffirmed 2019)	200	BDL
8	Total Dissolved Solids (TDS)	mg/litre	IS 3025(part 16)-1984 (Reaffirmed 2017)	500	18.52
9	Total Hardness (as CaCO ₃)	mg/litre	IS 3025(part 21)-2009 (Reaffirmed 2019)	200	13.98
10	Calcium (as Ca ²⁺)	mg/litre	IS 3025(part 40)-1991 (Reaffirmed 2019)	75	4.01
11	Magnesium (as Mg ²⁺)	mg/litre	IS 3025(part 46)-1994 (Reaffirmed 2019)	30	0.97
12	Chloride (as Cl ⁻)	mg/litre	IS 3025(part 32)-1988 (Reaffirmed 2019)	250	11.97
13	Flouride (as F ⁻)	mg/litre	IS 3025(part 01)-1984 (Reaffirmed 2017)	1.5	BDL
14	Iron (as Fe ²⁺)	mg/litre	IS 3025(part 01)-1984 (Reaffirmed 2017)	1	0.31
15	Nitrate (as NO ³⁻)	mg/litre	IS 3025(part 34)-1988 (Reaffirmed 2019)	45	4.18
16	Residual Chlorine	mg/litre	IS 3025(part 26)-1986 (Reaffirmed 2019)	0.2	NIL
17	Ammonia	mg/litre	IS 3025(part 34)-1988 (Reaffirmed 2019)	0.5	BDL

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Tested by

KWA/QCDL/MPM/R/01



Authorized By

Sanitary Chemist
Quality Control District Lab
Kerala Water Authority
Kottakkunnu, Malappuram.

Rev.No.00

Rev.Date: 00

Telephone No: 0483 2738735
email: qcdlmpm@gmail.com




KERALA WATER AUTHORITY
Quality Control District Laboratory, Kottakkunnu, Malappuram.

Water Analysis Report

Report No-KWA/QCDL/MPM/WAR/21-22/B 2438		Date: 27.10.2021			
Customer Name & Address		1. Sample Code	21-22/2438		
Hill Top Public School Kunnakkavu Elad (PO) Perinthalmanna		2. Date of Receipt	26.10.2021		
		3. Sampling Done by	Party		
		4. Source of Sample	Open Well		
		5. Sample Quantity	100 ml		
		6. Sample Performance from:	26.10.2021 to 27.10.2021		
Sl. No	Characteristics	Unit	Test Method	Available Limit as per IS 10500:2012	Results
1	Coliforms	CFU/100ml	IS 15185(part 1)2002 (Reaffirmed 2016)	ZERO	100
2	E-Coli	CFU/100ml	IS 15185(part 1)2002 (Reaffirmed 2017)	ZERO	ABSENT

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

TNTC- Too Numerous To Count




Tested By



കേരള സർക്കാർ

ശുചിത്വ സാക്ഷ്യപത്രം



നമ്പർ: 44/22

ഏലംകുളം ഗ്രാമപഞ്ചായത്തിലെ ഏലംകുളം വില്ലേജിലെ

23/2

സർവ്വേ/റീസർവ്വേ നമ്പരിലുള്ളതും.....9.....വാർഡിലെ 63A, 63B, 63C കെട്ടിട നമ്പരിൽ പ്രവർത്തിക്കുന്നതുമായ

ശ്രീ. ഹൈസൽ അലി - പി. ടി. ടി. ടി. ടി. ടി.

(മുഹമ്മദ് റിക് ട്രാപ്പ് പബ്ലിക് സ്കൂൾ)

പുഴക്കരയിൽ (M) മൂന്നാം നമ്പർ റോഡ് കൂലം എന്ന അപക്ഷേപകന്റെ

ഉടമസ്ഥതയിലുള്ള റിക് ട്രാപ്പ് പബ്ലിക് സ്കൂൾ, മൂന്നാം നമ്പർ റോഡ്, കൂലം.

റോഡ് കൂലം ഗ്രാമപഞ്ചായത്ത്, മലപ്പുറം ജില്ല എന്ന

സ്ഥാപനം വിദ്യാഭ്യാസ സ്ഥാപനം പ്രവർത്തനം

നടത്തുന്നതിനായി ഏർപ്പെടുത്തിയിരിക്കുന്ന ശുചിത്വ ക്രമീകരണങ്ങൾ 27.08.2022 തീയതിയിലെ

എന്റെ സന്ദർശന സമയത്ത് തൃപ്തികരമാണെന്ന് ഇതിനാൽ സാക്ഷ്യപ്പെടുത്തുന്നു.


ഐ.പി.എ.സി. ഐ.പി.എ.സി. ഐ.പി.എ.സി. ഐ.പി.എ.സി. ഐ.പി.എ.സി.

ഏലംകുളം ഗ്രാമപഞ്ചായത്ത് കാര്യാലയത്തിൽ 2022 21 വർഷത്തെ ഐ.പി.എ.സി. ഇ. & കെ.എസ്. നടത്തുന്ന

തിനുള്ള അനുമതിക്കായി അപേക്ഷയോടൊപ്പം സമർപ്പിക്കുന്നതിന് മാത്രമാണ് ഈ സാക്ഷ്യപത്രം നൽകുന്നത്.

മുഹമ്മദ് റിക് ട്രാപ്പ് പബ്ലിക് സ്കൂൾ വാർഡിൽ

1939ലെ മിസൈൽ പൊതുജനാരോഗ്യ നിയമത്തിലെ ഏതെങ്കിലും ശുചിത്വ വ്യവസ്ഥകളുടെ ലംഘനം സ്വയമേവ ഈ സാക്ഷ്യപത്രം റദ്ദാക്കുന്നതാണ്.



13.09.22

HEALTH INSPECTOR
ELAMKULAM PRIMARY HEALTH CENTRE
MALAPPURAM DISTRICT